

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/2025/ School/ NDZ/ 18

Dated: 14/01/2025

**FIRE SAFETY CERTIFICATE**

Certified that **Bhai Joga Singh Public School** located at **D-4, Faiz Road, New Delhi** comprises of **Ground + 03 upper floors** owned /occupied by **Bhai Joga Singh Public School** was earlier granted FSC by this department vide letter No. **F6/DFS/MS/2022/School/NDZ/405** dated 11/04/2022. Now, the premises was re-inspected by the officer concerned of this department on 31/12/2024 in the presence of the **Sh.Ved Sharma** and found that school with out auditorium, has deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the building premises is fit for occupancy of class Group B "**Educational Building**" without auditorium with effect from 14/01/2025 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/01/2025 at New Delhi by.

(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. Director of Education, Govt. of NCT, Old sect., Delhi.
3. The Principal, Bhai Joga Singh Public School at D-4, Faiz Road, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
8. Any flammable material for interior decoration shall strictly prohibited.